

## Clark County Building Department 4701 West Russell Road, Las Vegas, NV 89118 ~ (702) 455-3000

## **Duct/Area Detector Test Data**

James Gerren, P.E., Director Werner Hellmer P.E., Deputy Director 🗆 Scott Telford P.E., Deputy Director

DATE:			
CONTRACTOR NAME:			
T.A.B. APPROVED AGENCY:			
PERMIT NUMBER:			
JOB ADDRESS:			
JOB NAME/TENANT:			
EQUIPMENT TYPE:			
(Check One)	Duct Detectors	Area	Detectors
NUMBER OF DEVICES AT THIS LOCATION:			
MANUFACTURER'S AIRFLOW REQUIREMENTS: (When duct detectors are used).			
(CFM min.)	(CFM max.)		
ACTUAL AIRFLOW AS MEASURED AT DEVICE:			
EQUIPMENT AIRFLOW OUTPUT:			
(CFM or tonnage as shown on rating plate)			
EQUIPMENT SHUT OFF ACCOMPLISHED WHEN DEVICE PUT INTO ALARM:			
(Check one)	YES:	NO:	
TIME REQUIRED FOR SHUTOFF ONCE DEVICE SET IN ALARM:			
SECONDS:			(15 seconds max permitted time).
PERSON PERFORMING TEST:			
TITLE & AFFILIATION:			