



Clark County Department of Building & Fire Prevention

4701 West Russell Road, Las Vegas, NV 89118 ~ (702) 455-3000

Duct/Area Detector Test Data

Jerome A. Stueve, P.E., Director
Samuel D. Palmer P.E., Assistant Director • Girard W. Page, Fire Marshal

DATE: _____

CONTRACTOR NAME: _____

MECHANICAL PERMIT: _____

JOB NAME & ADDRESS: _____

TESTING EQUIPMENT TYPE: _____

Devices upon detection of smoke shall automatically shutoff air-moving
Equipment by interrupting the power source.

(Check one)

DUCT DETECTORS

AREA DETECTORS

NUMBER OF DEVICES AT THIS LOCATION: _____

MANUFACTURER'S NAME & MODEL NUMBER: _____

MANUFACTURER'S AIRFLOW REQUIREMENTS: (When duct detectors are used.)

(fpm min.) _____ (fpm max.) _____

ACTUAL AIRFLOW AS MEASURED AT DEVICE: _____

EQUIPMENT AIRFLOW OUTPUT: _____
(CFM or tonnage as shown on rating plate)

EQUIPMENT SHUT OFF ACCOMPLISHED WHEN DEVICE PUT INTO ALARM:

(Check one) YES: NO:

TIME REQUIRED FOR SHUTOFF ONCE DEVICE SET IN ALARM:

SECONDS: _____ (15 seconds max permitted time)

PERSON PERFORMING TEST: _____

TITLE & AFFILIATION: _____