



Department of Building & Fire Prevention

4701 W. Russell Road • Las Vegas, NV 89118
(702) 455-3000 • Fax (702) 221-0630

Jerome A. Stueve, P.E., Director
Samuel D. Palmer, P.E., Assistant Director • Jim Gerren, P.E., Assistant Director

April 28, 2021

NOTICE TO INDUSTRY

SUBJECT: SPRINKLER DESIGN SUBMITTAL REQUIREMENTS

Effective immediately, Clark County Fire Prevention will accept both fire hydrant flow tests and Las Vegas Valley Water District (LVVWD) hydraulic modeling for sprinkler design. Beginning August 1, 2021, fire hydrant flow tests will no longer be accepted. All fire sprinkler design submittals requiring hydraulic calculations must be submitted with the LVVWD hydraulic modeling results.

Respectfully,

Danny Horvat

Danny Horvat, Assistant Fire Chief
Fire Plans Check, Fire Prevention

DH:sas