



Clark County Building and Fire Prevention Field Inspection Division **FIELD INSPECTION GUIDELINE**

Division:	Inspections	Policy & Procedure:	FIG-E-011
Subject:	Show Window Receptacles	Effective Date:	01/05/2007
Code:	2017 NEC Section 210.62 Definition Article 100	Revised Date:	10/01/2020
Proposed:	Matthew Brewer	Approved:	Sam Palmer

Interpretation:

The NEC requires receptacle outlets to be installed directly above and within 18 inches of the top of show windows. One receptacle shall be installed for each 12 feet or major fraction thereof of the show window, measured horizontally.

Field Application:

The following guideline shall define when windows are to be considered show windows:

- For facilities with show room windows to be used as a display or advertisement, the facility design documents will be required to indicate this and shall have receptacles installed to comply with NEC 210.62.