Clark County Department of Building & Fire Prevention



4701 West Russell Road • Las Vegas NV 89118 (702) 455-3000 • Fax (702) 221-0630

Division:	Plans Examination & Inspection	Policy & Procedure:	BD-PP-151
Subject:	FIRE-RESISTANT PENETRATION AND JOINT REQUIREMENTS	Effective Date:	12/05/2014
Code:		Revised Date:	New

A. POLICY:

The architectural plans shall have a statement of special inspection to identify the requirements specified in IBC Section 1705.16.

B. PROCEDURE:

Architect of Record

- 1. Define the fire-rated assemblies and the hourly ratings within the structure.
- 2. Specify fire-resistant penetration and joint designs on the contract drawings to comply with the required hourly rating for the assembly being protected, or
 - Specify fire-resistant penetration and joint designs as a deferred submittal on the contract drawings.
- 3. Provide to the general contractor listings of CCBD reviewed and accepted fire-resistant penetration and joint designs.

Plans Examination staff shall

- 1. Review drawings for conditions which require special inspection in accordance with IBC Section 1705.16.
 - Ensure product specification(s) and the listing designation(s) for fire-resistant penetrations, fire-resistant joints systems and perimeter fire barrier systems are shown on the approved plans. This may be accepted as a deferred submittal, when specifically noted as such.
 - In high-rise buildings (occupiable floor of more than 55' above fire department vehicle access) or in buildings assigned to *Risk Category* III or IV in accordance with Section 1604.5
- 2. Specify the special inspection requirement in Naviline as Item Y
- 3. Review and accept fire-resistant penetration and joint design submittals.
 - The review can be limited to a range of listed designs applicable to the typical conditions anticipated in the construction. The typical conditions may be penetrations, head-of-wall, wall joints, and edge-of-slab.
 - The designs must take into account the framing systems (materials), penetration materials, joint geometry and the range of hourly ratings.
 - The submittal may be in a letter format or full size plan sheets with a tabular layout such that any condition in the field may be addressed in the table.
 - Copies of the specific designs identified in the table are not required to be supplied with the deferred submittal.

Installing contractor shall:

Division:	Plans Examination & Inspection	Policy & Procedure	BD-PP-151
Subject:	FIRE-RESISTANT PENETRATION and JOINT REQUIREMENTS	Effective Date:	12/05/2014
Code:	N/A	Revised Date:	New

- 1. Maintain a copy of the CCBD accepted designs issued by the Architect.
- 2. Procure and maintain copies of the listing documents for use by the building inspector and special inspector.
- 3. Contractors are required to schedule an initial inspection with the special inspector.
- 4. Arrange for all installers to perform verification inspections with the special inspector.

Inspection staff:

- 1. The jurisdiction building inspector shall confirm the specific listing selected for use in the field is appropriate.
- 2. The special inspector shall verify and document installation in accordance with the specific design and compliance to the required hourly rating for the assembly being protected.
- 3. The jurisdiction building inspector shall approve the final assembly.
- 4. The special inspection final report shall be reviewed and accepted by CCBD inspection staff prior to final building inspection.

Revision History:

POLICY #	TITLE	Effective Date	Revised	Reviewed
BD-PP-151	Fire-Resistant Penetration and Joint	12/05/2014	2/05/2014 New	
	Requirements	12/03/2014		

Developed by:	Reviewed by:			
Brian Lenihan Sr. Engineer/Architect	Ted Droessler Kevin McOsker Brenda Thompson Engineering Manager Plans Exam Manager Inspection Manager			
Reviewed by:	Approved by:			
Samuel D. Palmer, P.E. Assistant Director	Ronald L. Lynn Director/Building & Fire Official			