



Clark County Building Department

4701 West Russell Road ▪ Las Vegas NV 89118

(702) 455-3000 ▪ Fax (702) 455-5810

Division:	Building Division – Plans Exam	Policy & Procedure	BP-PP-072
Subject:	NATURAL GAS PIPE SIZING	Effective Date:	05/01/2007
Code:	UPC 1217.4	Revised Date:	

A. POLICY

This policy and procedure addresses natural gas pipe sizing values as required by Southwest Gas Corporation. The Uniform Plumbing Code, Section 1217.4, states that "...standard delivery pressure shall have prior verification from the gas supplier..."

B. PROCEDURE

1. The appropriate value for use in the Las Vegas Valley is 1,000 BTU's per cubic foot of natural gas.

Revision History:

POLICY #	TITLE	Effective Date	Revised	Reviewed
PE-PP-UPC-005	Natural Gas Pipe Sizing	May 1, 2007		
BP-PP-072	Natural Gas Pipe Sizing			August 15, 2008
BP-PP-072	Natural Gas Pipe Sizing			September 13, 2013

Approved by:

Ronald L. Lynn, Director/Building & Fire Official

Concurred by:

Gregory J. Franklin, Assistant Director