

Nonroad engines that are not dual purpose and/or self-propelled **cannot** remain at one location for more than 12 consecutive months. Engines remaining at one location for 12 consecutive months or more are considered stationary engines, therefore subject to 40 CFR Part 63, Subpart ZZZZ, and must be included in a Division of Air Quality permit as emission units. Shorter timelines apply if engines are located at a seasonal source.

If an engine replaces an engine at a location and is intended to perform the same or similar function as the engine replaced, you must include the time period of both engines in calculating the consecutive time period.

Storage means the engine has been removed from any service. Just because the engine is not operating (i.e, is turned off), that doesn't qualify as "storage." Moving equipment in storage to your boneyard is recommended.

Source ID#: _____

Source Name:

Engine Identification	Location	Operating or Storage?	Function	Start Date	End Date
Manufacturer, Model/Serial #	GPS coordinates (lat & long)	O/S	What is it powering?	Date	Date

