



CLARK COUNTY FIRE DEPARTMENT - FIRE PREVENTION BUREAU

4701 W Russell Rd, Las Vegas, NV 89118 • (702) 455-7316

Website: [Fire Department \(clarkcountynv.gov\)](http://FireDepartment(clarkcountynv.gov))

Email: FPPCQ@clarkcountynv.gov

Permit Submittal Guideline

Fireworks Booth Operation Permit by Inspector

Permit Use:

This guide is to assist in the permitting process for fireworks booth operations. Permit is required to set up and use for sales a fireworks booth

APPLICABLE CODES:

The following codes and standard apply to this permit:

- *Clark County International Fire Code, 2024 edition (IFC) Amendments*

Link to CCFC: See the amendments to codes and standards using the link below:

webfiles.clarkcountynv.gov//Fire/Fire

[Prevention/Library/Chapter 13.04 THE FIRE CODE OF CLARK COUNTY.pdf](http://Prevention/Library/Chapter_13.04_THE_FIRE_CODE_OF_CLARK_COUNTY.pdf)

SUBMITTAL REQUIREMENTS:

No items are required to be submitted as part of this permit. Permit conditions shall be field verified to meet the requirements below.

PERMIT BY INSPECTION ELIGIBILITY:

1. Always maintain clear exits.
2. Extinguisher is to be mounted and have a current service tag.
3. Storage is allowed under shelves only.
4. Aisle must be always kept clear.
5. Canopies may be placed against the booth but may not be attached to the booth.
6. Tarps may be attached to the roof with screws and cannot overhang more than 1 foot from the top.
7. Cooking is prohibited within 50 feet.
8. Smoking is prohibited within 50 feet.
9. No parking within 10 feet of the booth
10. All personnel working within the booth must sign the Guideline Signature sheet, stating that they understand the guidelines.
11. There must always be two personnel in the booth, no more than 4 and at least one person must be 18 years of age. No Pets.
12. No one under 16 years of age is allowed within the booth.
13. Certificate of Insurance: The permittee shall furnish a certificate of insurance for hazard coverage of at least \$1,000,000 or greater as specified by the Fire Prevention Bureau

Booth Location:

1. Be at least 10 feet from air and water dispensers and the curb or roadway.
2. Be at least 20 feet from underground fuel tank fill ports, generators, fuel storage, fireworks storage, tents and any building.
3. Be at least 30 feet away from combustible materials.



CLARK COUNTY FIRE DEPARTMENT - FIRE PREVENTION BUREAU

4701 W Russell Rd, Las Vegas, NV 89118 • (702) 455-7316

Website: [Fire Department \(clarkcountynv.gov\)](http://FireDepartment(clarkcountynv.gov))

Email: FPPCQ@clarkcountynv.gov

Permit Submittal Guideline

4. Be at least 50 feet from ignition sources, motor vehicle fuel dispensers, propane dispensers and above ground storage tanks.

Booth Construction:

1. No stand/booth shall exceed 33 feet in length or 10 feet in width.
2. All stands shall have no less than two unobstructed exits measuring a minimum of 6 feet tall and 2 feet in width. The counter shall not be considered an exit.
3. The siding and roof of the booths shall be made of a minimum of ¼-inch plywood or comparable material or of noncombustible materials.
4. All wiring and appliances shall meet the requirements of the National Electrical Code and be protected from damage.
5. Overhead wiring powering fireworks stands/booths shall be a minimum of 13 feet, 6 inches above grade.
6. Trailers used as fireworks stands/booths may be used when approved.

The following items must always be onsite.

-Folder containing: -Fireworks Booth Orientation Form, - Southern Nevada Association Guidelines, - Guideline Signature Sheet with the checklist on the back, - Permit that is issued following the inspection, -Inventory list of approved products, -No smoking signs must be posted.

PERMIT DURATION:

Fireworks stands/booths shall be operated from June 28th to July 4th of every calendar year.

To apply for your permit please visit your customer ACA account and apply for a temporary permit, then select fireworks booth from the drop-down menu. [Accela Citizen Access](#)